

CONTAMINANTS	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	RANGE Low   High		Sample Date	Violation	Typical Source
DISINFECTANTS & DISINFECTION BY-PRODUCTS: (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl2) (ppm)	4	4	1.34	0.25	2.00	2020	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	33	13	41	2020	No	By-product of drinking water chlorination
Total Trihalomethanes (TTHMs) (ppb)	NA	80	52	13	53	2020	No	By-product of drinking water disinfection
Total Organic Carbon (ppm)	NA	TT	0.88	0.68	0.95	2020	No	Naturally present in the environment
INORGANIC CONTAMINANTS:								
Fluoride (ppm)	4	4	0.69	0.22	0.94	2020	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate + Nitrite (as nitrogen) (ppm)	10	10	0.27	0.23	0.30	2020	No	Runoff from fertilizer use, leaching from septic tanks, sewage, erosion of natural deposits
Barium (ppb)	2000	2000	5.5	0	11	2020	No	Discharge of drilling wastes and metal refineries; erosion of natural deposits.
MICROBIOLOGICAL CONTAMINANTS:								
Turbidity (NTU)	NA	At least 95% below 0.3 NTU	100% below 0.3, Highest value 0.23	NA	NA	2020	No	Soil runoff
RADIOACTIVE CONTAMINANTS:								
Radium (combined 226/228) (pCi/L)	NA	5	0.3	0	0.6	2015	No	Erosion of natural deposits

CONTAMINANTS	MCLG	AL	Your Water	# Samples Exceeding AL	Sample Date	Exceeds AL	Typical Source
INORGANIC CONTAMINANTS:							
Copper - action level at consumer taps (ppb)	1300	1300	27	0	2018	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	2	0	2018	No	Corrosion of household plumbing systems; Erosion of natural deposits